



**Diamondback
Engineering & Surveying**

12640 West Cedar Drive, Suite C,
Lakewood, CO 80228
Office: 303-985-4204
Fax: 303-985-4214

www.diamondbackeng.com

December 17, 2009

Mr. Robert Swenson
Mr. Bruce Anderson
Facsimile Original

Re: Spring Creek Ranch Sanitary Sewer System

Dear Bob and Bruce,

I have reviewed the sewer system narrative prepared by Bob Swenson and agree with the system adequacy as presented therein.

As stated in the narrative, there don't appear to be any operational or maintenance problems with the existing systems. The lot sizing and building envelope locations are nicely situated to accommodate individual disposal systems on the seven currently undeveloped lots. No improvements are required at the gray water lagoon system since most water entering the lagoons is evaporating prior to discharging from the first lagoon.

Please feel free to contact me with any questions.

Sincerely,

John Enochs, President
Diamondback Engineering and Surveying, Inc.