

**Send to:** Division of Water Resources  
1313 Sherman Street, Room 818  
Denver, Colorado 80203

**Fax:** 303-866-3589  
**Phone:** 303-866-3581



**OWNER'S NOTICE OF CONSTRUCTED WELL**



Construction of my well under **Permit No.** 64629-F was  
completed on \_\_\_\_\_,  
(month) (day) (year)

The well was constructed by: Unknown  
(drilling contractor)

**If the pumping equipment has been installed.....**

The pump was installed in my well by: Abbot Pump  
(pump contractor)  
on November, 2005  
(month) (day) (year)

**Signed:**

Robert Swenson - President Spring Creek Ranchers Assoc.

**Date:**

**Phone:** (303) 807-3876

**The well must be constructed and pump installed by licensed water well construction and pump installation contractors, OR**

**PLEASE BE ADVISED** that, pursuant to section 37-91-106(3), C.R.S. (2003), any person who intends to construct his/her own well or to install pumping equipment in a well as a "private driller" or "private pump installer" shall be required to comply with minimum construction standards adopted by the Board of Examiners of Water Well Construction and Pump Installation Contractors. (See Construction Rules, 2 CCR 402-2.)

Form No. GWS-25

OFFICE OF THE STATE ENGINEER  
COLORADO DIVISION OF WATER RESOURCES

818 Centennial Bldg., 1313 Sherman St., Denver, Colorado 80203  
(303) 866-3581

LIC

WELL PERMIT NUMBER 64629 -F-  
DIV. 5 WD 36 DES. BASIN MD

APPLICANT

SPRING CREEK RANCHERS ASSN INC  
C/O CALOIA HOUPPT & HAMILTON PC  
1204 GRAND AVE  
GLENWOOD SPRINGS, CO 81601-

(970) 945-6067

APPROVED WELL LOCATION

SUMMIT COUNTY  
NE 1/4 SE 1/4 Section 7  
Township 2 S Range 80 W Sixth P.M.

DISTANCES FROM SECTION LINES

1390 Ft. from South Section Line  
425 Ft. from East Section Line

UTM COORDINATES (Meters, Zone:13,NAD83)

Easting: Northing:

PERMIT TO USE AN EXISTING WELL

ISSUANCE OF THIS PERMIT DOES NOT CONFER A WATER RIGHT

CONDITIONS OF APPROVAL

- 1) This well shall be used in such a way as to cause no material injury to existing water rights. The issuance of this permit does not ensure that no injury will occur to another vested water right or preclude another owner of a vested water right from seeking relief in a civil court action.
- 2) Construction details for this existing well have not been provided to this office; therefore, it is not known if the construction of this well is in compliance with the Water Well Construction Rules, 2 CCR 402-2. The issuance of this permit does not relieve the well owner of responsibility or liability in the event contamination of the groundwater source results from the construction or use of this well, nor does the State Engineer assume any responsibility or liability should contamination occur.
- 3) Approved pursuant to CRS 37-90-137(2) for the use of an existing well on the condition that this well is operated in accordance with the Spring Creek Ranch Augmentation Plan approved by the Division 5 Water Court in Case No. 93CW213. If this well is not operated in accordance with the terms of said decree, it will be subject to administration including orders to cease diverting water.
- 4) The pumping rate of this well shall not exceed 100 GPM.
- 5) The average annual amount of ground water to be appropriated shall not exceed 17.16 acre-feet.
- 6) The use of ground water from this well is limited to domestic use in 14 single-family dwellings, irrigation of 4.27 acres (13,300 sq. ft. per residence), and domestic animal watering (up to 3 horses per lot).
- 7) The owner shall mark the well in a conspicuous place with well permit number(s), name of the aquifer, and court case number(s) as appropriate. The owner shall take necessary means and precautions to preserve these markings.
- 8) A totalizing flow meter must be installed on this well and maintained in good working order. Permanent records of all diversions must be maintained by the well owner (recorded at least annually) and submitted to the Division Engineer upon request.
- 9) This well shall be located not more than 200 feet from the location specified on this permit.
- 10) This well shall be located at least 600 feet from any existing well, completed in the same aquifer, that is not owned by the applicant.
- 11) This well shall not be pumped unless included in a court approved plan for augmentation or a substitute water supply plan approved by the State Engineer. *CPL 7-25-2006*

APPROVED  
CJL

  
State Engineer

  
By

Receipt No. 0545862

DATE ISSUED 07-25-2006

EXPIRATION DATE 07-25-2007